

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHJECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod litem 129/2, Troja, 182 00 Praha 8

## CERTIFICATE

No.: 1240441

**Product:** Electrical Insulating Blanket

**Type:** EIP0-1,0x0

**Rating:** class 0, category A, Z

**Ordering firm:** BOGUMA, s. r. o.  
Továrenská 314, 95618 Bošany, Slovakia

**Manufacturer:** BOGUMA, s. r. o.  
Továrenská 314, 95618 Bošany, Slovakia

**Trade mark:**

The test results are stated in the test-report No.: 241920-01/01 of: 28.08.2024

A sample of the product was found to be in conformity with:

ČSN EN 61112:2010 (idt. IEC 61112:2009)

cl. 5.2.2, 5.2.3, 5.2.5, 5.3, 5.5.2, 5.5.3, 5.5.4, 5.6.2.2, 5.6.2.3, 5.6.4.2, 5.6.4.3, 5.7, 5.8.1, 5.8.2, 6.2, 6.4

**Other data:**

The validity of the certificate is limited to: 04.09.2027

05.09.2024

Prague

**SIGNATURE**

Mgr. Miroslav Sedláček  
Head of Certification Body

**STAMP**



241920-01